

N/C

Receipt No.

Livingston County Health Department  
204 S. Highlander Way, Howell, Michigan 48843  
(517) 546-9850

314,408  
I.D. No.

Prop. Description No.

### SOILS EVALUATION— SUBSURFACE SEWAGE DISPOSAL SYSTEMS

Location and Directions: North of CIVE ROAD on west side

AI BORATYNSKI  
Owner

JANE  
Requestor

SOIL DESCRIPTION				SKETCH	
Ft.	(1)	(2)	(3)	Ft.	
1	TOPSOIL	TOPSOIL	TOPSOIL	1	<p>North</p> <p>MARK RD</p> <p>③ ±125'    ② 80'    ① ±165'</p> <p>175'</p> <p>165'</p>
2	sandy loam	clay loam	clay loam	2	
3				3	
4				4	
5				5	
6		medium sandy gravel	medium sandy gravel	6	
7	medium sand/gravel			7	
8				8	
9				9	
10				10	
11				11	
12				12	

- Suitable
- Unsuitable
- Suitable with Special Restrictions
- Further Info. Needed (Refer to Comments)

Comments: locate the system in the area of soil borings

install system to ± 6ft backfill with a clean sharp sand, then lay pipe and tie, 36" maximum cover

[Signature]  
Environmental Health Representative

4/26/88  
Date

Soils evaluation based on criteria stated in Livingston County Sanitary Code, effective May 1, 1986.

This is NOT a permit. A suitable soils rating is NOT a guarantee that a permit to construct an on-site subsurface sewage disposal system will be granted. Changing conditions that might result in permit denial are explained in more detail on the reverse side.

Location: MARK RD  
Township: OSCEOLA  
Section No.: 4  
Subdivision/Acreage: 2 Acres  
Lot, Parcel: 2